



Emergency Lighting Test Switch



Features:

- Complies with AS2293.1-2005 clause 4.3.1.
- Adjustable time (0.1s to 10 days).
- Manual test/normal/reset operation.
- 25A (AC1), 4 normally closed contacts.
- Pre-wired control circuit.

Part No.

- **ELTS4:** open type for use in distribution boards.
- **ELTSK4:** enclosed, key operated system.

**NEW
PRODUCT**

